



## THE LEND – KITCHEN AND BAR (AT THE LEND HOTEL)

Grüne Gasse 2

8020 Graz

T +43 316 71 70 00

[office@lendhotel.at](mailto:office@lendhotel.at)

[www.lendhotel.at](http://www.lendhotel.at)

The Lend Hotel, located in the heart of the hip Lend quarter, also has a trendy café which serves great food and drink to both hotel guests and visitors throughout the day. The extensive breakfast menu, created with fresh ingredients from the market next door, will give you a boost for the whole day. From 12:00–21:00 hrs, Smørrebrød, the Danish classic, is served in several varieties. Quinoa bowls are also on the menu from lunchtime to dinner time. When time is of the essence: Coffee-to-go is no problem, and when it's getting late: The bar in the open lobby serves drinks around the clock.

### ACCESSIBILITY

#### Accessibility by public transport

Please use the route planner of the Styria Public Transport Network (Verbundlinie Steiermark): <https://verkehrsankunft.verbundlinie.at/>

#### Parking

- Short-stay parking zone in the surrounding streets

### ENTRANCE AREA

- Path to the entrance very short, mostly at least 150 cm wide (exceptions: public footpath 90 cm and terrace on the ground floor 90 cm)
- Easy to drive on, level, without steps or thresholds
- Not free of obstacles (however, passage width of 90 cm is available)
- The lateral boundary (stones) and change of surface provide a kind of tactile surface guidance system
- Continuously illuminated

## ENTRANCE:

- Entrance **not easy to find**
- The accessible entrance is a main entrance, covered
- Automatic hinged door, **does not open in advance and does not close with a time delay, door pivot range not marked on the floor**
- Glass door, **not sufficiently marked**
- Clear width at least 90 cm, no thresholds
- Dust control mat suitable for wheelchairs



Entrance

## CAFÉ-RESTAURANT:

- Completely level and without thresholds
- Tables have under-table wheelchair access (at least 80 cm wide, 70 cm high, 60 cm deep)
- There is at least 100 cm space between the occupied chairs
- Seats have no armrests; seat height standard (46–50 cm)
- **Counter height 96 cm, no lowered desk**
- Sufficient space for movement in front of the counter (at least 150 x 150 cm)
- High chair available
- Activities available for children
- Facility **not free from carpets, upholstered furniture or curtains**
- Tables with glare-free lighting also available
- Menu in large, contrasting, easy to read font
- Drinking straws available to order
- Low-calorie offers, offers for food allergy sufferers (gluten-free, various types of milk)
- Accessible WC in the basement (accessible by lift)
- Accessible outdoor dining area



Café/counter



Café



Café

### SLIDING DOORS AT TERRACE:

- Glass door, not sufficiently marked
- Does not stand out in high contrast from adjacent fixtures
- Clear door width at least 90 cm
- **Door not easy to open**; in the warm time of the year it is open, however, staff are pleased to help
- **Door threshold present** (max. 2 cm high, threshold not two-sided)
- Lever handle at standard height (85–110 cm)
- Lateral access area of 50 cm available inside adjacent to the door handle, but not outside (displaced by tables)
- Access area of at least 150 x 120 cm on both sides of the door available

### ACCESSIBLE WC (BASEMENT)

Level, accessible via elevator; separately arranged (unisex)

#### Door

- Hinged door, 90 cm clear door width, no threshold
- Opens to the outside, can be unlocked from the outside in an emergency
- **Not easy to open** (3.4 kg instead of max. 2.5 kg), **automatic door closer**
- On opening side **access area of 200 x 150 cm not given**
- On closing side **access area of 150 x 120 cm not given**
- Access area of at least 50 cm on both sides of the door next to the door handle
- Door handle at standard height



## WC

- Movement area of 150 x 150 cm available in the room
- WC accessible from left, at least 90 cm of space (78 cm on the right)
- At least 120 cm of space in front of WC
- WC bowl at standard height (46–48 cm)
- Folding support rail on left at standard height (75–85 cm)
- Flusher and paper can be reached from the WC when sitting
- Emergency bell available (emergency call to reception), accessible from the WC while seated

## Washbasin

- At standard height, under-table wheelchair access
- Movement area of at least 120 x 120 cm in front of the washbasin
- Plastic siphon
- Tap fitting easy to reach
- **Mirror is too high**
- Equipment such as soap dispenser, towel dispenser, etc. at standard height



Accessible WC

## LIFT:

- Accessible without threshold
- Movement area on entry and exit at least 150 x 150 cm
- Clear door width 93 cm, light barriers at max. 100 cm
- Width of lift car at least 110 cm, depth at least 140 cm
- Pushbuttons (inside and outside) touchable, with raised lettering and in Braille
- Use of the pushbuttons is confirmed with audible and visual signal
- Display large and high contrast
- When the lift arrives, **no audible signal or announcement**
- Emergency call also confirmed visually
- Handrail available
- No downward staircase opposite lift door



Lift

#### ADDITIONAL INFO:

- Free wifi
- Guide dogs are welcome
- **No evacuation concept** for people with disabilities
- Audible alarm system, but no visible alarm
- No baby changing table available in the general accessible WC

Validity: May 2018, errors and omissions excepted



Source: [http://www.bereit-fuer-barrierefreiheit.eu/de/Betriebe/?xt=CEDOSCheckResults&xtMethod=showDataset&cat\\_id=1455&tobj\\_id=3089&show\\_details=1&show\\_catalogue=1#catalogue](http://www.bereit-fuer-barrierefreiheit.eu/de/Betriebe/?xt=CEDOSCheckResults&xtMethod=showDataset&cat_id=1455&tobj_id=3089&show_details=1&show_catalogue=1#catalogue)